
STAMFORD AVK

HV 804 R WDG 83 - Technical Data Sheet



FRAME HV 804 R





STANDARDS

Cummins Generator Technologies industrial generators meet the requirements of BS EN 60034 and the relevant sections of other national and international standards such as BS5000, VDE 0530, NEMA MG1-32, IEC60034, CSA C22.2-100, AS1359.

Other standards and certifications can be considered on request.

DESCRIPTION

The STAMFORD PI range of synchronous ac generators are brushless with a rotating field. They are separately excited by the STAMFORD Permanent Magnet Generator (PMG). This is a shaft mounted, high frequency, pilot exciter which provides a constant supply of clean power via the Automatic Voltage Regulator (AVR) to the main exciter. The main exciter output is fed to the main rotor, through a full wave bridge rectifier, protected by surge suppression.

VOLTAGE REGULATORS

The P80 range generators complete with a PMG are available with one AVR. Underspeed protection (UFRO) is also provided by the AVR. The UFRO will reduce the generator output voltage proportional to the speed of the generator below a pre-settable level.

The STAMFORD | AvK Digital Excitation Control System (DM110) is an electronic, solid-state, microprocessor based control device. The DM110 regulates the output voltage of a the ac generator by controlling the current into the generator exciter field. Input power to the DM110 is provided by a multi-pole, high-frequency, permanent magnet generator (PMG).

The DM110 is supplied in an encapsulated package designed for behind-the-panel mounting. Front panel indicators (LEDs) annunciate DM110 status and system conditions. DM110 connections are made through quarterinch, quick-connect terminals on the rear panel. A 9-pin DB-9 type connector on the rear panel provides communication between the DM110 and an IBM compatible PC.

Technical details on the DM110 are available on the Stamford-AvK website using the following URL: https://www.stamford-avk.com/downloads/avr-manuals

WINDINGS & ELECTRICAL PERFORMANCE

All generator stators are wound to 2/3 pitch. This eliminates triplen (3rd, 9th, 15th ...) harmonics on the voltage waveform and is found to be the optimum design for trouble-free supply of non-linear loads. The 2/3 pitch design avoids excessive neutral currents sometimes seen with higher winding pitches. A fully connected damper winding reduces oscillations during paralleling. This winding, with the 2/3 pitch and carefully selected pole and tooth designs, ensures very low levels of voltage waveform distortion.

TERMINALS & TERMINAL BOX

Standard generators feature a main stator with 6 ends brought out to the terminals, which are mounted on the frame at the non-drive end of the generator. A sheet steel terminal box contains the AVR and provides ample space for the customers' wiring and gland arrangements. It has removable panels for easy access.

SHAFT & KEYS

All generator rotors are dynamically balanced to better than BS6861:Part 1 Grade 2.5 for minimum vibration in operation. Two bearing generators are balanced with a half key.

INSULATION/IMPREGNATION

The insulation system is class 'F'.

All wound components are impregnated with materials and processes designed specifically to provide the high build required for static windings and the high mechanical strength required for rotating components.

QUALITY ASSURANCE

Generators are manufactured using production procedures having a quality assurance level to BS EN ISO 9001.

NOTE ON REGULATION

The stated voltage regulation may not be maintained in the presence of certain radio transmitted signals. Any change in performance will fall within the limits of Criteria 'B' of EN 61000-6-2:2001. At no time will the steady-state voltage regulation exceed 2%.

NB Continuous development of our products entitles us to change specification details without notice, therefore they must not be regarded as binding.

Front cover drawing is typical of the product range.

STAMFORD AVK


FRAME HV 804 R


WINDING 83

RATINGS	REFER TO SALES AND SERVICE BRIEFING				
MAXIMUM ALTITUDE	1000 METRES ABOVE SEA LEVEL				
MAXIMUM AMBIENT TEMPERATURE	40º C				
CONTROL SYSTEM SERIES 3	SEPARATELY EXCITED BY P.M.G.				
A.V.R.	FULL WAVE RECTIFIED				
VOLTAGE REGULATION	± 0.25%				
SUSTAINED SHORT CIRCUIT	REFER TO SHORT CIRCUIT DECREMENT O	CURVES OF THIS SECTION			
INSULATION SYSTEM		CLASS F			
PROTECTION	IP23 STANDARD				
RATED POWER FACTOR		0.8			
STATOR WINDING	DOUBLE LAYER LAP				
WINDING PITCH	2/3				
WINDING LEADS	6				
R.F.I. SUPPRESSION	BS EN 50081/2-1/2 VDE 0875G VDE 0875N For other standards apply to the factory				
WAVEFORM DISTORTION	NO LOAD < 1.5% NON-DIST	FORTING BALANCED LINEAR LOAD < 3.0%			
MAXIMUM OVERSPEED	2250 Rev/Min				
BEARING DRIVE END	ISO 6232 C3				
BEARING NON DRIVE END		ISO 6324 C3			
EFFICIENCY	REFER TO EFFICIE	ENCY CURVES OF THIS SECTION			
FREQUENCY	50Hz				
TELEPHONE INTERFERENCE		THF< 2%			
COOLING AIR		3.0 m ³ /sec			
VOLTAGE STAR (Y)	10500	11000			
kVA BASE RATING FOR	0107	0070			
REACTANCE VALUES	2167	2270			
Xd DIRECT AXIS SYNCHRONOUS	2.535	2.420			
X'd DIRECT AXIS TRANSIENT	0.220	0.210			
X"d DIRECT AXIS SUB-TRANSIENT	0.164	0.157			
Xq QUADRATURE AXIS REACTANCE	1.792	1.710			
X"q QUAD. AXIS SUB-TRANSIENT	0.304	0.290			
XL LEAKAGE REACTANCE	0.124	0.118			
X2 NEGATIVE PHASE SEQUENCE	0.236	0.225			
X ₀ ZERO PHASE SEQUENCE	0.035	0.033			
REACTANCES ARE SATURATED	VALUES ARE PER UNIT	AT RATING AND VOLTAGE INDICATED			
T'd TRANSIENT TIME CONSTANT		0.200			
T"d SUB-TRANSIENT TIME CONSTANT		0.015			
T'do O.C. FIELD TIME CONSTANT		4.000			
Ta ARMATURE TIME CONSTANT	0.060				
SHORT CIRCUIT RATIO	1/Xd				
STATOR WINDING RESISTANCE (L-N)		0.6010			
ROTOR WINDING RESISTANCE	1.320				
EXCITER STATOR FIELD RESISTANCE	17.50				
EXCITER ROTOR RESISTANCE (L-L)	0.076				
PMG STATOR RESISTANCE (L-L)	3.800				
- \	RESISTANCE VALUES ARE IN OHMS AT 20° C				
NO LOAD EXCITATION VOLTAGE	15.0				
FULL LOAD EXCITAION VOLTAGE		63.0			


Continuous development of our products entitles us to change specification details without notice, therefore they must not be regarded as binding.

THREE PHASE EFFICIENCY CURVES






FULL WAVE RECTIFIED AVR LOCKED ROTOR MOTOR STARTING CURVE



FRAME HV 804 R WDG 83 50Hz

Three Phase Short Circuit Decrement Curve No- Load Excitation at Rated Speed

Based on series star (wye) connection



NOTE 1

THE FOLLOWING MULTIPLICATION FACTORS SHOULD BE USED TO ADJUST THE VALUES FROM CURVES BETWEEN THE 0.001 SECONDS AND THE MINIMUM CURRENT POINT IN RESPECT OF NOMINAL OPERATING VOLTAGE

VOLTAGE	FACTOR
10500V	X 0.95
11000V	X 1.00

THE SUSTAINED CURRENT VALUE IS CONSTANT IRRESPECTIVE OF VOLTAGE LEVEL

NOTE 2

THE FOLLOWING MULTIPLICATION FACTORS SHOULD BE USED TO CONVERT THE VALUES CALCULATED IN ACCORDANCE WITH NOTE 1 TO THOSE APPLICABLE TO THE VARIOUS TYPES OF SHORT CIRCUIT

3 PHASE	2 PHASE L-L	1 PHASE L-N
X 1.0	X 0.87	X 1.30
X 1.0	X 1.80	X 3.20
X 1.0	X 1.50	X 2.50
10 SEC	5 SEC	2 SEC
	X 1.0 X 1.0 X 1.0	X 1.0 X 0.87 X 1.0 X 1.80 X 1.0 X 1.50

SUSTAINED SHORT CIRCUIT = 429 Amps

FRAME HV 804 R

STAMFORD AvK


WINDING 83

0.8 Power Factor

RATINGS

Class - Temp Rise	Cont. F - 105/40 ℃		Class F Standby - 125/40 ℃		Class F Standby - 138/27℃			
50 Hz r (V)	10500	11000	10500	11000	10500	11000		
kVA	2167	2270	2320	2430	2405	2520		
kW	1734	1816	1856	1944	1924	2016		
Efficiency (%)	95.7	95.8	95.6	95.7	95.6	95.8		
kW Input	1811	1895	1941	2032	2013	2104		
60 Hz	N/A	N/A	N/A	N/A	N/A	N/A		
kVA	N/A	N/A	N/A	N/A	N/A	N/A		
kW	N/A	N/A	N/A	N/A	N/A	N/A		
Efficiency (%)	N/A	N/A	N/A	N/A	N/A	N/A		
kW Input	N/A	N/A	N/A	N/A	N/A	N/A		

TYPICAL DIMENSIONS - Further arrangements available - please refer to factory



STAMFORD AVK