

For maximum performance of your alternator

STAMFORD | AvK "

POWERING TOMORROW, TOGETHER

#### Introduction

Scheduled service and repair are vital to the reliable operation of your alternator and the safety of those who come in contact with it.

The service activities included in this guide are intended to maximise the life of the alternator, but will not vary, extend or change the terms of the manufacturer's standard warranty or your obligations in that warranty.

Each service interval should be used as a guide only, and developed on the basis that the alternator was installed and is operated in accordance with the manufacturer's guidelines. If the alternator is located and/or

operated in adverse or unusual environmental conditions, the service intervals may need to be more frequent. The alternator should be continually monitored between service to identify any potential failure modes, signs of misuse, or excessive wear and tear.

Find your local Authorised STAMFORD I AvK Parts and Service Dealer at:

www.stamford-avk.com



#### Disclaimer

This guide contains guidance and instructions for servicing and maintenance of the alternator only.

Before operating the alternator, refer to the Installation, Service and Maintenance manual to make sure that all personnel who work on the equipment have access to the manual and all additional documentation supplied with it. Misuse and failure to follow the instructions, and the use of non-approved parts, may invalidate the product warranty and lead to potential accidents.

The manual is an essential part of the alternator and should be available to all users throughout its life.

This guide states service intervals and key components to inspect throughout the life of the alternator. Refer to the full instructions in the Installation, Service & Maintenance manual when servicing the alternator.

This guide is written for skilled electrical and mechanical technicians and engineers, who have prior knowledge and experience of generating equipment of this type. If in doubt, please seek expert advice or contact your local Cummins Generator Technologies subsidiary.

#### Notice

Information in this guide was correct at time of going to print. It may be superseded due to our policy of continuous improvement.

Please visit:

www.stamford-avk.com for latest documentation.



#### Safety Precautions



#### Safety Information and Notices

Danger, Warning and Caution panels are used in this manual to describe the sources of hazards, their consequences and how to avoid injury. Notice panels emphasize important or critical instructions.

#### **DANGER**

Danger indicates a hazardous situation which, if not avoided, WILL result in death or serious injury.

#### **↑** WARNING

Warning indicates a hazardous situation which, if not avoided, COULD result in death or serious injury.

#### **↑** CAUTION

Caution indicates a hazardous situation which, if not avoided, COULD result in minor or moderate injury.

#### NOTICE

Caution indicates a hazardous situation which, if not avoided, COULD result in minor or moderate injury.



#### **General Guidance**

#### NOTICE

These safety precautions are for general guidance and supplement your own safety procedures and all applicable laws and standards.

#### Skill Requirements of Personnel

Service and maintenance procedures must only be carried out by experienced and qualified engineers, who are familiar with the procedures and the equipment.

#### Risk Assessment

A risk assessment has been performed on this product by Cummins, however a separate risk assessment must be performed by the user/operating company to establish all personnel-related risks. All affected users must be trained on the identified risks. Access to the Power PlanUGenerator Set during operation must be restricted to persons who have been trained on these risks.



#### Personal Protective Equipment (PPE)

All persons operating, servicing, maintaining or working in or with a power plant or a generator set must wear appropriate Personal Protective Equipment (PPE) Recommended PPE includes:

- Ear and Eye Protection
- Head and face protection
- Safety footwear
- Overalls that protect the lower arms and legs

Ensure that all persons are fully aware of the emergency procedures in case of accidents.

#### Noise

#### **↑** WARNING

Noise from a running alternator can cause serious injury by permanent hearing damage. To prevent injury, wear appropriate personal protection equipment (PPE).

Maximum A-weighted noise emissions depend on alternator type. Contact the supplier for application-specific details.



#### **Electrical Equipment**

#### DANGER

Live electrical conductors can cause serious injury or death by electric shock and burns. To prevent injury and before removing covers over electrical conductors, isolate the generator set from all energy sources, remove stored energy and use lock out/tag out safety procedures.

All electrical equipment can be dangerous if not operated correctly. Always install, service and maintain the alternator in accordance with this manual. Work that requires access to electrical conductors must comply with all applicable local and national electrical safety procedures for the voltages involved and any site specific rules. Always use genuine branded replacement parts.

#### Lock Out/Tag Out

#### **⚠** WARNING

#### **Reconnected Energy Source**

Accidental reconnection of energy sources during service and maintenance work can cause serious injury or death by electric shock, burns, crushing, severing or trapping.

To prevent injury and before starting service and maintenance work, use appropriate lock out/tag out safety procedures to keep the generator set isolated from energy sources. Do not defeat or bypass the lock out/tag out safety procedures.



#### Lifting

#### **DANGER**

Falling mechanical parts can cause serious injury or death by impact, crushing, severing or trapping. To prevent injury and before lifting:

- Check the capacity, condition and attachment of lifting equipment (crane, hoists and jacks, including attachments to anchor, fix or support the equipment).
- Check the capacity, condition and attachment of accessories for lifting (hooks, slings, shackles and eye bolts for attaching loads to lifting equipment).
- Check the capacity, condition and attachment of lifting fixtures on the load.
- Check the mass, integrity and stability (e.g. unbalanced or shifting center of gravity) of the load.

#### **↑** WARNING

Falling mechanical parts can cause serious injury or death by impact, crushing, severing or trapping.

To prevent injury and before lifting the alternator:

- . Do not lift the complete generator set by the alternator lifting fixtures.
- Keep the alternator horizontal when lifting.
- Fit drive end and non-drive end transit fittings to single bearing alternators to keep the main rotor in the frame.

Do not remove the lifting label attached to one of the lifting points.



#### **Alternator Operating Areas**

#### **↑** WARNING


Debris ejected during catastrophic failure can cause serious injury or death by impact, severing or stabbing.

To prevent injury:

- . Keep away from the air inlet and air outlet when the alternator is running.
- Do not put operator controls near the air inlet and air outlet.
- . Do not cause overheating by running the alternator outside rating plate parameters.
- . Do not overload the alternator.
- Do not run an alternator with excessive vibration.
- Do not synchronize parallel alternators outside the specified parameters.

Always wear suitable PPE when working in the hatched areas shown in the diagram or directly in-line with any air inlet/outlet.

Make sure this consideration is captured in your risk assessment.





#### **Hazard Warning Labels**

#### **↑** WARNING

Safety Cover Removed

A hazard exposed when a safety cover is removed can cause serious injury or death.

To prevent injury:

- Fit the safety labels at the locations shown on the back of the label sheet supplied.
- Observe the safety labels.
- · Refer to the service manual before removing covers.

The generator set manufacturer is responsible for fitting the self-adhesive hazard warning labels supplied with the alternator.

Replace labels that are missing, damaged or painted over.



#### **Hazard Warning Labels - continued**



## PO/P1 Alternator



# PO/P1 Alternator

Commission Post Commission 1,000 Hour 10,000 Hours 30,000 Hours 6 Month Service 1 Year Service 2 Year Service 5 Year Service

_
-
_
π
_
_
_
-
9
-
÷
_
~
_
÷
$\mathbf{a}$
=
_
_
=
$\mathbf{a}$

#### ommissio

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect	Inspect	Inspect	Inspect
Alternator  Inspect  Alternator rating  Bedplate arrangement  Coupling arrangement  Environmental conditions and cleanliness  Complete machine damage, loose parts and earth bonds  Guards, screens, warning and safety labels  Maintenance access	<ul> <li>Synchronisation settings</li> <li>Test</li> <li>Initial AVR set up</li> <li>AVR settings while alternator is running</li> <li>Customer connections of auxiliaries</li> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	Condition of windings Customer settings for temperature sensors  Test Insulation resistance of all windings (P0/P1 test for LV) Insulation resistance of rotor, exciter and EBS Temperature sensors while alternator is running	<ul> <li>Condition of bearings</li> <li>Customer settings for temperature sensors</li> <li>Test</li> <li>Temperature sensors while alternator is running</li> </ul>
<ul> <li>Ambient temperature (inside and outside)</li> </ul>	Cooling	Rectifier	Terminal Box
and outside)  Electrical nominal operating conditions and excitations while alternator is running  Vibration while alternator is running	Inspect  Air flow (rate and direction while alternator is running)  Condition of fan  Test  Condition of air filter	Inspect ■ Diodes and varistors	Inspect ■ All alternator/customer ■ Connections and cabling

#### Post Commission 250 Hours/6 Months

Alternator	Controls and Auxiliaries	Windings	Bearings
nspect	Test	Inspect	Inspect
Environmental conditions and cleanliness     Complete machine damage, loose parts, and earth bonds     Guards, screens, warning and safety labels      Ambient temperature (inside and outside)     Electrical nominal operating conditions and excitations	AVR settings while alternator is running     Function of auxiliaries     Synchronisation while alternator is running	<ul> <li>Condition of windings</li> <li>Test</li> <li>Insulation resistance of all windings (P0/P1 test for LV)</li> <li>Insulation resistance of rotor, exciter and EBS</li> <li>Temperature sensors while alternator is running</li> </ul>	■ Condition of bearings
while alternator is running	Cooling	Rectifier	Terminal Box
Vibration while alternator is			
running	Inspect Condition of fan  Test Condition of air filter	Inspect ■ Diodes and varistors	Inspect  All alternator/customer connections and cabling
	Clean  Air filter		

	=
	-
C	۲
9	
3	_
0	Ľ
+	=
_	-
<	1
	7
т	_
c	L
=	_
-	-
≍	7
	L

#### 1,000 Hours/1 Year Service

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect	Test	Inspect	Inspect
<ul><li>Environmental conditions and cleanliness</li></ul>	<ul> <li>AVR settings while alternator is running</li> </ul>	Condition of windings	Condition of bearings
<ul> <li>Complete machine damage, loose parts, and earth bonds</li> <li>Guards, screens, warning and safety labels</li> <li>Test</li> <li>Ambient temperature (inside and outside)</li> </ul>	Customer connections of auxiliaries     Function of auxiliaries     Synchronisation while alternator is running	■ Insulation resistance of all windings (P0/P1 test for LV) ■ Insulation resistance of rotor, exciter, and EBS ■ Temperature sensors while alternator is running	■ Temperature sensors while alternator is running
<ul> <li>Electrical nominal operating conditions and excitations while alternator is running</li> </ul>			
Vibration while alternator is	Cooling	Rectifier	Terminal Box
running	Inspect	Inspect	Inspect
	Condition of fan	■ Diodes and varistors	<ul> <li>All alternator/customer connections and cabling</li> </ul>
	Test		
	Condition of air filter		
	Clean		
	■ Air filter		

#### 10,000 Hours/2 Year Service

?	10,000 nours/2 rear service	;		
5	Alternator	Controls and Auxiliaries	Windings	Bearings
3	Inspect	Inspect	Inspect	Inspect
	Coupling arrangement	Anti condensation heater	Condition of windings	Condition of bearings
	<ul> <li>Environmental conditions and cleanliness</li> <li>Complete machine damage, loose parts, and earth bonds</li> <li>Guards, screens, warning and safety labels</li> <li>Test</li> <li>Ambient temperature (inside and outside)</li> </ul>	Test  AVR settings while alternator is running  Customer connections of auxiliaries  Function of auxiliaries  Synchronisation while alternator is running	Test ■ Insulation resistance of all windings (PO/P1 test for LV) ■ Temperature sensors while alternator is running	
	<ul> <li>Electrical nominal operating conditions and excitations while alternator is running</li> </ul>	Cooling	Rectifier	Terminal Box
	■ Vibration while alternator is	Inspect	Inspect	Inspect
	running	<ul><li>Condition of fan</li><li>Test</li><li>Condition of air filter</li></ul>	■ Diodes and varistors	<ul> <li>All alternator/customer connections and cabling</li> </ul>
		Clean		
		■ Air filter		

#### P0/P1 Alternator 30,000 Hours/5 Year Service Kits

For the 30,000 hour service interval we recommend replacing several components in order to optimise the alternator's performance.

For the P0/P1 alternator, the kits detailed in this table contain all parts necessary to execute the maintenance and repairs.

Kit Number	Contents
<b>A051C107</b> (P0/P1 1 Bearing 30,000 Hour Service Kit)	■ Rectifier Service Kit ■ NDE Bearing Kit
<b>A051C115</b> P0/P1 2 Bearing 30,000 Hour Service Kit)	Rectifier Service Kit  DE and NDE Bearing Kit

Frame	Part Number	Description
P0/P1	45-1161	Heater Kit UL 230V
P0/P1	45-1162	Heater Kit UL 115V
P0/P1	45-1163	Heater Kit UL 24V
P0/P1	45-1164	Heater Kit UL 12V

#### 30,000 Hours/5 Year Service

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect	Replace	Inspect	Replace
Coupling arrangement	Anti condensation heater	■ Condition of windings	■ Bearings
<ul> <li>Environmental conditions and cleanliness</li> <li>Complete machine damage, loose parts, and earth bonds</li> <li>Guards, screens, warning and safety labels</li> <li>Test</li> <li>Ambient temperature (inside and outside)</li> </ul>	Test  AVR settings while alternator is running  Customer connections of auxiliaries  Function of auxiliaries  Synchronisation while alternator is running	Insulation resistance of all windings (P0/P1 test for LV)     Temperature sensors while alternator is running     Insulation resistance of rotor, exciter and EBS	
<ul> <li>Electrical nominal operating conditions and excitations while alternator is running</li> </ul>	Cooling	Rectifier	Terminal Box
Vibration while alternator is running	Inspect ■ Condition of fan  Test ■ Condition of Air filter	Replace Diodes and varistors	Inspect ■ All alternator/customer connections and cabling

#### SO/S1 Alternator



## SO/S1 Alternator

Commission Post Commission 1,000 Hour 10,000 Hours 30,000 Hours 6 Month Service 1 Year Service 2 Year Service 5 Year Service

•	_
•	_
-	_
•	τ
-	_
- 5	-
- 3	_
	٠.
٠,	ľ
•	_
-	-
2	1
	•
т	_
ė.	^
u	7
-	
-	-
•	_
	7
u	٠.

#### Commission

3	Commission			
<u> </u>	Alternator	Controls and Auxiliaries	Windings	Bearings
AILEIIIAU	Inspect	Test	Inspect	Inspect
30/31 A	<ul> <li>Alternator rating</li> <li>Bedplate arrangement</li> <li>Coupling arrangement</li> <li>Environmental conditions and cleanliness</li> <li>Complete machine damage, loose parts and earth bonds</li> <li>Guards, screens, warning and safety labels</li> <li>Maintenance access</li> </ul> Test	<ul> <li>Initial AVR set up</li> <li>AVR settings while alternator is running</li> <li>Customer connections of auxillaries</li> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	Condition of windings  Test Insulation resistance of all windings (SO/S1 test for LV) Insulation resistance of rotor, exciter and auxiliary	■ Condition of bearings
	Ambient temperature (inside	Cooling	Rectifier	Terminal Box
	and outside)  Electrical nominal operating conditions and excitations while alternator is running  Vibration while alternator is running	Inspect Air flow (rate and direction while alternator is running) Condition of fan	Inspect Diodes and varistors	Inspect ■ All alternator/customer connections and cabling

#### Post Commission 250 Hours/6 Months

POST COMMISSION 200 HOURS	S/O WOTHIS		
Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect	Test	Inspect	Inspect
<ul><li>Environmental conditions and cleanliness</li></ul>	<ul> <li>AVR settings while alternator is running</li> </ul>	■ Condition of windings	Condition of bearings
<ul> <li>Complete machine damage, loose parts, and earth bonds</li> </ul>	Function of auxiliaries	Test  ■ Insulation resistance of all	
■ Guards, screens, warning		windings (S0/S1 test for LV)	
and safety labels		<ul> <li>Insulation resistance of rotor, exciter and auxiliary</li> </ul>	
Test			
<ul> <li>Ambient temperature (inside and outside)</li> </ul>			
<ul> <li>Electrical nominal operating conditions and excitations</li> </ul>			
while alternator is running	Cooling	Rectifier	Terminal Box
■ Vibration while alternator is			
running	Inspect	Inspect	Inspect
	Condition of fan	■ Diodes and varistors	<ul> <li>All alternator/customer connections and cabling</li> </ul>

-23	4
	•
σ	3
2	
_	
ā	2
-	3
×	=
2	ľ
•	L
_	-
u	)
≺	_
_	3
_	2
7	í
v	J

#### ☐ 1,000 Hours/1 Year Service

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect	Test	Inspect	Inspect
■ Environmental conditions and cleanliness	<ul> <li>AVR settings while alternator is running</li> </ul>	■ Condition of windings	Condition of bearings
Complete machine damage, loose parts, and earth bonds Guards, screens, warning	<ul><li>Customer connections of auxiliaries</li><li>Function of auxiliaries</li></ul>	Test  ■ Insulation resistance of all windings (S0/S1 test for LV)	
and safety labels		rotor, exciter, and auxiliary	
Test		<ul> <li>Temperature sensors while alternator is running</li> </ul>	
<ul> <li>Ambient temperature (inside and outside)</li> </ul>			
■ Electrical nominal operating conditions and excitations			
while alternator is running	Cooling	Rectifier	Terminal Box
	Inspect	Inspect	Inspect
.ug	■ Condition of fan	■ Diodes and varistors	<ul> <li>All alternator/customer connections and cabling</li> </ul>
	Inspect  Environmental conditions and cleanliness  Complete machine damage, loose parts, and earth bonds  Guards, screens, warning and safety labels  Test  Ambient temperature (inside and outside)  Electrical nominal operating conditions and excitations	Inspect ■ Environmental conditions and cleanliness ■ Complete machine damage, loose parts, and earth bonds ■ Guards, screens, warning and safety labels  Test ■ Ambient temperature (inside and outside) ■ Electrical nominal operating conditions and excitations while alternator is running ■ Vibration while alternator is running ■ Vibration while alternator is running  Test  Test ■ AVR settings while alternator is running ■ Customer connections of auxiliaries ■ Function of auxiliaries ■ Function of auxiliaries ■ Cooling ■ Cooling ■ Inspect	Inspect  Environmental conditions and cleanliness  Complete machine damage, loose parts, and earth bonds  Guards, screens, warning and safety labels  Test  Ambient temperature (inside and outside)  Electrical nominal operating conditions and excitations while alternator is running  Vibration while alternator is running  Test  Inspect  Condition of windings  Test  Insulation resistance of all windings (SO/S1 test for LV)  Insulation resistance of rotor, exciter, and auxiliary  Temperature sensors while alternator is running  Cooling  Rectifier  Inspect

#### ≥ 10,000 Hours/2 Year Service

Alternator	Controls and Auxiliaries	Windings	Bearings
Coupling arrangement Environmental conditions and cleanliness Complete machine damage, loose parts, and earth bonds Guards, screens, warning and safety labels	Inspect  Anti condensation heater  Test  AVR settings while alternator is running  Customer connections of auxiliaries  Function of auxiliaries	Inspect ■ Condition of windings  Test ■ Insulation resistance of all windings (SO/S1 test for LV)	Inspect ■ Condition of bearings
Ambient temperature (inside and outside)      Electrical nominal operating conditions and excitations	Cooling	Rectifier	Terminal Box
while alternator is running  Vibration while alternator is running	Inspect ■ Condition of fan	Inspect ■ Diodes and varistors	Inspect ■ All alternator/customer connections and cabling

#### S0/S1 Alternator 30,000 Hours/5 Year Service Kits

For the 30,000 hour service interval we recommend replacing several components in order to optimise the alternator's performance.

For the S0/S1 alternator, the kits detailed in this table contain all parts necessary to execute the maintenance and repairs.

Kit Number	Contents
A051C107 (S1 Bearing 30,000 Hour Service Kit)	■ Rectifier Service Kit ■ NDE Bearing Kit
A054N489 (S0 Bearing 30,000 Hour Service Kit)	■ Rectifier Service Kit ■ NDE Bearing Kit

Frame	Part Number	Description
S0/S1	A054K278	Heater Kit UL 12V
S0/S1	A054K280	Heater Kit UL 24V
S0/S1	A054K282	Heater Kit UL 115V
S0/S1	A054K284	Heater Kit UL 230V

#### 30,000 Hours/5 Year Service

Alternator	Controls and Auxiliaries	Windings	Bearings
nspect	Replace	Inspect	Replace
Coupling arrangement Environmental conditions and cleanliness Complete machine damage, loose parts, and earth bonds Guards, screens, warning and safety labels  Cest Ambient temperature (inside and outside)	<ul> <li>Anti condensation heater</li> <li>Test</li> <li>AVR settings while alternator is running</li> <li>Customer connections of auxiliaries</li> <li>Function of auxiliaries</li> </ul>	Condition of windings  Test Insulation resistance of all windings (S0/S1 test for LV) Insulation resistance of rotor, exciter and auxiliary	■ Bearings
Electrical nominal operating conditions and excitations while alternator is running	Cooling	Rectifier	Terminal Box
Vibration while alternator is running	<ul><li>Inspect</li><li>Condition of fan</li><li>Test</li><li>Condition of Air filter</li></ul>	Replace  Diodes and varistors	Inspect  All alternator/customer connections and cabling

## UC22/UC27 Alternator



## UC22/UC27

**Alternator** 

Commission

Post Commission 6 Month Service

1,000 Hour 1 Year Service 10,000 Hours 2 Year Service 30,000 Hours 5 Year Service



•	-
•	-
•	-
C	۲
- 2	-
- 5	_
- 5	_
7	ī
٠,	-
-	=
_	5
<	3
	7
_	٠
2	3
c	
=	
_	
<	-
_	
C	٦
	٠
•	3
c	
3	=
	-
_	-

#### ommissio

Alternator	Controls and Auxiliaries	Windings	Bearings
nspect	Inspect	Inspect	Inspect
Alternator rating     Bedplate arrangement     Coupling arrangement     Environmental conditions and cleanliness     Complete machine damage, loose parts and earth bonds     Guards, screens, warning and safety labels     Maintenance access	<ul> <li>Synchronisation settings</li> <li>Test</li> <li>Initial AVR set up</li> <li>AVR settings while alternator is running</li> <li>Customer connections of auxiliaries</li> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	Condition of windings  Customer settings for temperature sensors  Test  Insulation resistance of all windings (UC22/UC27 test for LV/MV)  Temperature sensors while alternator is running	<ul> <li>Condition of bearings</li> <li>Customer settings for temperature sensors</li> <li>Test</li> <li>Temperature sensors while alternator is running</li> </ul>
lest est			
<ul> <li>Ambient temperature (inside and outside)</li> </ul>	Cooling	Rectifier	Terminal Box
Electrical nominal operating conditions and excitations while alternator is running     Vibration while alternator is running	Inspect  Air flow (rate and direction while alternator is running)  Condition of fan  Test  Condition of air filter	Inspect Diodes and varistors Three phase rectifier (if fitted)	Inspect  All alternator/customer connections and cabling

#### Post Commission 250 Hours/6 Months

1 oot oonmission 200 Hours/o Monaio			
Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect	Test	Inspect	Inspect
<ul> <li>Environmental conditions and cleanliness</li> </ul>	<ul> <li>AVR settings while alternator is running</li> </ul>	■ Condition of windings	■ Condition of bearings
<ul> <li>Complete machine damage, loose parts, and earth</li> </ul>	■ Function of auxiliaries	Test	Test
bonds	<ul> <li>Synchronisation while alternator is running</li> </ul>	■ Insulation resistance of all windings (UC22/UC27 test	■ Temperature sensors while alternator is running
<ul> <li>Guards, screens, warning and safety labels</li> </ul>		for LV/MV)	anomator to ranning
•		Insulation resistance of rotor, exciter and PMG	
Test		■ Temperature sensors while	
<ul> <li>Ambient temperature (inside and outside)</li> </ul>		alternator is running  Insulation resistance of	
<ul> <li>Electrical nominal operating conditions and excitations</li> </ul>		rotor, exciter and PMG	
while alternator is running	Cooling	Rectifier	Terminal Box
■ Vibration while alternator is			
running	Inspect	Inspect	Inspect
	Condition of fan	■ Diodes and varistors	<ul> <li>All alternator/customer connections and cabling</li> </ul>
	T	Three phase rectifier (if fitted)	connections and cabing
	Test	,	
	Condition of air filter		

#### 1,000 Hours/1 Year Service

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect  Environmental conditions and cleanliness  Complete machine damage, loose parts, and earth bonds  Guards, screens, warning and safety labels  Test  Ambient temperature (inside and outside)	Test  AVR settings while alternator is running  Customer connections of auxiliaries  Function of auxiliaries  Synchronisation while alternator is running	Inspect Condition of windings  Test Insulation resistance of all windings (UC22/UC27 test for LV/MV) Insulation resistance of rotor, exciter, and PMG Temperature sensors while alternator is running	Inspect Condition of bearings  Test Temperature sensors while alternator is running
<ul> <li>Electrical nominal operating conditions and excitations while alternator is running</li> <li>Vibration while alternator is running</li> </ul>	Cooling Inspect Condition of fan  Test Condition of air filter  Clean Air filter	Rectifier  Inspect Diodes and varistors Three phase rectifier (if fitted)	Terminal Box Inspect ■ All alternator/customer connections and cabling

#### 10,000 Hours/2 Year Service

Alternator	Controls and Auxiliaries	Windings	Bearings
Coupling arrangement Environmental conditions and cleanliness Complete machine damage, loose parts, and earth bonds Guards, screens, warning and safety labels  Test Ambient temperature (inside	Inspect  Anti condensation heater  Test  AVR settings while alternator is running  Customer connections of auxiliaries  Function of auxiliaries  Synchronisation while alternator is running	Inspect ■ Condition of windings  Test ■ Insulation resistance of all windings (UC22/UC27 test for LV/MV ■ Temperature sensors while alternator is running	Inspect Condition of bearings  Test Temperature sensors while alternator is running
and outside)  Electrical nominal operating conditions and excitations while alternator is running  Vibration while alternator is running	Cooling Inspect Condition of fan  Test Condition of air filter  Clean Air filter	Rectifier  Inspect Diodes and varistors Three phase rectifier (if fitted)	Terminal Box  Inspect ■ All alternator/customer connections and cabling

#### UC22/UC27 Alternator 30,000 Hours/5 Year Service Kits

For the 30,000 hour service interval we recommend replacing several components in order to optimise the alternator's performance.

For the UC22/UC27 alternator, the kits detailed in this table contain all parts necessary to execute the maintenance and repairs.

Kit Number	Contents
A051C212 (UC22 1 Bearing 30,000 Hour Service Kit)	■ Rectifier Service Kit ■ NDE Bearing Kit
<b>A051C216</b> (UC22 2 Bearing 30,000 Hour Service Kit)	■ Rectifier Service Kit ■ DE and NDE Bearing Kit
<b>A051C218</b> (UC27 1 Bearing 30,000 Hour Service Kit)	■ Rectifier Service Kit ■ DE and NDE Bearing Kit
A051C222 (UC27 2 Bearing 30,000 Hour Service Kit)	■ Rectifier Service Kit ■ DE and NDE Bearing Kit

Frame	Part Number	Description	
UC22/UC27	A053N107	Heater Kit UL 110-125V	
UC22/UC27	A053N108	Heater Kit UL 220-260V	


#### 30,000 Hours/5 Year Service

Alternator	Controls and Auxiliaries	Windings	Bearings
Coupling arrangement     Coupling arrangement     Environmental conditions and cleanliness     Complete machine damage, loose parts, and earth bonds     Guards, screens, warning and safety labels    Guards	Replace Anti condensation heater  Test AVR settings while alternator is running Customer connections of auxiliaries Function of auxiliaries Synchronisation while alternator is running	Inspect Condition of windings  Test Insulation resistance of all windings (UC22/UC27 test for LV/MV) Temperature sensors while alternator is running Insulation resistance of rotor, exciter and PMG	Replace Bearings  Test Temperature sensors while alternator is running
Electrical nominal operating conditions and excitations while alternator is running     Vibration while alternator is running	Cooling Inspect Condition of fan  Test Condition of air filter	Rectifier  Replace  Diodes and varistors	Terminal Box  Inspect ■ All alternator/customer connections and cabling

### HC4/HC5/HC6 Alternator

## HC4/HC5/HC6

**Alternator** 



Commission F

Post Commission 6 Month Service

1,000 Hour 1 Year Service 10,000 Hours 2 Year Service 30,000 Hours 5 Year Service



		=
	c	-
	£	_
	'n	
	2	١
	S	
	ī	
	•	ľ
	č	
	Ξ	
	-	i
- 7	-	۰
•		•
•	•	٠
(	_	
	-	
	-	۰
- 7	7	2
ı	3	i
•	•	i
•	=	
-	1	
٠	₹	
	_	ì
	٠	į
- (	•	1
-	=	
	_	

#### ommissio

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect	Inspect	Inspect	Inspect
Alternator rating     Bedplate arrangement     Coupling arrangement     Environmental conditions and cleanliness     Complete machine damage, loose parts and earth bonds     Guards, screens, warning and safety labels     Maintenance access	Synchronisation settings  Test Initial AVR and PFC set up AVR and PFC settings while alternator is running Customer connections of auxiliaries Function of auxiliaries Synchronisation while alternator is running	Condition of windings  Customer settings for temperature sensors  Test  Insulation resistance of all windings (HC4/HC5/HC6 test for LV/MV)  Temperature sensors while alternator is running	Condition of bearings  Customer settings for temperature sensors  Test  Temperature sensors while alternator is running
<ul> <li>Ambient temperature (inside and outside)</li> </ul>	Cooling	Rectifier	Terminal Box
Electrical nominal operating conditions and excitations while alternator is running     Vibration while alternator is running	Inspect  Air flow (rate and direction while alternator is running)  Condition of fan  Test  Condition of air filter	Inspect ■ Diodes and varistors	Inspect ■ All alternator/customer connections and cabling

#### Post Commission 250 Hours/6 Months

A	Alternator	Controls and Auxiliaries	Windings	Bearings
3 1	nspect	Test	Inspect	Inspect
5	<ul> <li>Environmental conditions and cleanliness</li> </ul>	<ul> <li>AVR and PFC settings while alternator is running</li> </ul>	Condition of windings	Condition of bearings
	loose parts, and earth bonds Guards, screens, warning and safety labels  Fest Ambient temperature (inside and outside) Electrical nominal operating	Function of auxiliaries     Synchronisation while alternator is running	■ Insulation resistance of all windings (HC4/HC5/HC6 test for LV/MV) ■ Insulation resistance of rotor, exciter and PMG ■ Temperature sensors while alternator is running ■ Insulation resistance of rotor, exciter and PMG	Test  Temperature sensors while alternator is running  Clean Grease exhaust and trap (Re-greasable bearings only)  Replace Grease for re-greasable bearings
	conditions and excitations while alternator is running	Cooling	Rectifier	Terminal Box
•	Vibration while alternator is running	Inspect ■ Condition of fan  Test ■ Condition of air filter  Clean ■ Air filter	Inspect ■ Diodes and varistors	Inspect ■ All alternator/customer connections and cabling

_
•
-
π
- 22
_
_
ā
u
+
=
4
_
·
•
•
┰
_
-
Ľ
7
_
∓
_
~
_
7
•
_
т
_

#### 1,000 Hours/1 Year Service

1	Alternator	Controls and Auxiliaries	Windings	Bearings
	Environmental conditions and cleanliness     Complete machine damage, loose parts, and earth bonds     Guards, screens, warning and safety labels  Test     Ambient temperature (inside and outside)     Electrical nominal operating	Test  AVR and PFC settings while alternator is running  Customer connections of auxiliaries  Function of auxiliaries  Synchronisation while alternator is running	Inspect Condition of windings  Test Insulation resistance of all windings (HC4/HC5/HC6 test for LV/MV) Insulation resistance of rotor, exciter, and PMG Temperature sensors while alternator is running	Test  Temperature sensors while alternator is running  Replace Bearing greasee  Clean Grease exhaust and trap
	conditions and excitations while alternator is running  Vibration while alternator is running	Cooling Inspect Condition of fan  Test Condition of air filter  Clean Air filter	Rectifier  Inspect Diodes and varistors	Terminal Box  Inspect ■ All alternator/customer connections and cabling

#### 10,000 Hours/2 Year Service

Alternator	Controls and Auxiliaries	Windings	Bearings
Coupling arrangement     Environmental conditions and cleanliness     Complete machine damage, loose parts, and earth bonds     Guards, screens, warning and safety labels  Test     Ambient temperature (inside and outside)	Inspect  Anti condensation heater  Test  AVR and PFC settings while alternator is running  Customer connections of auxiliaries  Function of auxiliaries  Synchronisation while alternator is running	Inspect ■ Condition of windings  Test ■ Insulation resistance of all windings (HC4/HC5/HC6 test for LV/MV) ■ Temperature sensors while alternator is running	Test  Temperature sensors while alternator is running  Replace Bearing grease  Clean Grease exhaust and trap
Electrical nominal operating conditions and excitations while alternator is running     Vibration while alternator is running	Cooling Inspect Condition of fan  Test Condition of air filter  Clean Air filter	Rectifier  Inspect Diodes and varistors	Terminal Box  Inspect ■ All alternator/customer connections and cabling

#### HC4/HC5/HC6 Alternator 30,000 Hours/5 Year Service Kits

For the 30,000 hour service interval we recommend replacing several components in order to optimise the alternator's performance.

For the HC4/HC5/HC6 alternator, the kits detailed in this table contain all parts necessary to execute the maintenance and repairs.

Frame	Part Number	Description
HC4	A053M965	Heater Kit UL 220-260\
HC4	A053M957	Heater Kit UL 110-125\
HC5/HC6	A053N002	Heater Kit UL 220-260\
HC5/HC6	A053M968	Heater Kit UI 110-125V

	Kit Number	Contents
	A051C225 (HC4 1 Bearing 30,000 Hour Service Kit)	<ul><li>Rectifier Service Kit</li><li>NDE Bearing Kit</li></ul>
	A051C230 (HC4 2 Bearing 30,000 Hour Service Kit)	■ Rectifier Service Kit ■ DE and NDE Bearing Kit
	A051C232 (HC5 1 SEALED Bearing 30,000 Hour Service Kit)	Rectifier Service Kit NDE Bearing Kit
	A051Z125 (HCS 1 RE-GREASABLE Bearing 30,000 Hour Service Kit)	Rectifier Service Kit Re-grease NDE Bearing Kit Cartridge and Cap
	A051C234 (HC5 2 SEALED Bearing 30,000 Hour Service Kit)	Rectifier Service Kit DE and NDE Bearing Kit Cartridge and Cap
	A051Z131 (HC5 2 RE-GREASABLE Bearing 30,000 Hour Service Kit)	Rectifier Service Kit     Regrease DE and NDE Bearing Kit     Cartridge and Cap
	A051C237 (HC6 1 SEALED Bearing 30,000 Hour Service Kit)	Rectifier Service Kit NDE Bearing Kit Cartridge and Cap
1	A051Z133 (HC6 1 RE-GREASABLE Bearing 30,000 Hour Service Kit)	Rectifier Service Kit Re-grease NDE Bearing Kit Cartridge and Cap
1	A051C243 (HC6 2 SEALED Bearing 30,000 Hour Service Kit)	Rectifier Service Kit DE and NDE Bearing Kit Cartridge and Cap
	A051Z137 (HC6 2 RE-GREASABLE Bearing 30,000 Hour Service Kit)	Rectifier Service Kit     Regrease DE and NDE Bearing Kit     Cartridge and Cap

#### **♂** 30,000 Hours/5 Year Service

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect	Replace	Inspect	Replace
<ul><li>Coupling arrangement</li><li>Environmental conditions</li></ul>	Anti condensation heater	Condition of Windings	Bearings (sealed & re-greasable
and cleanliness  Complete machine damage,	Test ■ AVR and PFC settings while	Test Insulation resistance of all	■ Bearing grease
loose parts, and earth bonds  Guards, screens, warning	alternator is running  Customer connections of	windings (HC4/HC5/HC6 test for LV/MV)	Test ■ Temperature sensors while
and safety labels	auxiliaries  Function of auxiliaries	Temperature sensors while alternator is running     Insulation resistance of	alternator is running
Test  ■ Ambient temperature (inside	<ul> <li>Synchronisation while alternator is running</li> </ul>	rotor, exciter and PMG	Clean  ■ Grease exhaust & trap
and outside)  Electrical nominal operating			(re-greasable bearings only)
conditions and excitations while alternator is running	Cooling	Rectifier	Terminal Box
■ Vibration while alternator is running	Inspect  ■ Condition of fan	Replace  Diodes and varistors	Inspect ■ All alternator/customer connections and cabling
	Test		
	Condition of air filter		
	Clean		
	Air filter		

#### S4/S5/S6 Alternator

## S4/S5/S6 Alternator

Commission Post Commission 1,000 Hour 6 Month Service 1 Year Service

000 Hour 10,000 Par Service 2 Year S

10,000 Hours 30,000 Hours 2 Year Service 5 Year Service



_
u
œ
•
▾
~
c,

#### Commission

A Ir	Iternator	Controls and Auxiliaries	Windings	Bearings
lr	nspect	Inspect	Inspect	Inspect
00/00/10	Environmental conditions and cleanliness     Complete machine damage, loose parts and earth bonds	Synchronisation settings  Test Initial AVR and PFC set up AVR and PFC settings while alternator is running Customer connections of auxiliaries Function of auxiliaries Synchronisation while alternator is running	Condition of windings  Customer settings for temperature sensors  Test Insulation resistance of all windings Temperature sensors while alternator is running	<ul> <li>Condition of bearings</li> <li>Customer settings for temperature sensors</li> <li>Test</li> <li>Temperature sensors while alternator is running</li> </ul>
•	Ambient temperature (inside and outside)	Cooling	Rectifier	Terminal Box
•	and outside)    Electrical nominal operating conditions and excitations while alternator is running   Vibration while alternator is running	Inspect Air flow (rate and direction while alternator is running) Condition of fan  Test Condition of air filter	Inspect ■ Diodes and varistors	Inspect ■ All alternator/customer connections and cabling

#### Post Commission 250 Hours/6 Months

Alternator  Controls and Auxiliaries  Windings  Inspect  Environmental conditions and cleanliness  AVR and PFC settings while alternator is running  Condition of win		
Controls and Auxiliaries	Windings	Bearings
Test	Inspect	Inspect
<ul> <li>AVR and PFC settings while alternator is running</li> </ul>	Condition of windings	Condition of bearings
Guards, screens, warning and safety labels  Test  Ambient temperature (inside and outside)	Insulation resistance of all windings     Insulation resistance of rotor, exciter and PMG     Temperature sensors while alternator is running     Insulation resistance of	Test ■ Temperature sensors while alternator is running  Clean ■ Grease exhaust and trap (Re-greasable bearings only)  Replace ■ Grease for re-greasable
Cooling	Rectifier	bearings  Terminal Box
Inches	lana at	l
■ Condition of fan  Test ■ Condition of air filter  Clean ■ Air filter	■ Diodes and varistors	■ All alternator/customer connections and cabling
	Test  AVR and PFC settings while alternator is running Function of auxiliaries Synchronisation while alternator is running  Cooling Inspect Condition of fan  Test Condition of air filter  Clean	Test  AVR and PFC settings while alternator is running Function of auxiliaries Synchronisation while alternator is running  Insulation resistance of all windings Insulation resistance of rotor, exciter and PMG Temperature sensors while alternator is running Insulation resistance of rotor, exciter and PMG Rectifier  Cooling Rectifier Inspect Condition of fan  Inspect Diodes and varistors  Test Condition of air filter  Clean

4	F	
(	٦	
•	Ė	
1	L	
9	J	
2		
<	1	i
	7	
¢	ς	
٥	1	
Ļ	ì	
_	•	:
•	•	ı
C	1	

#### □ 1,000 Hours/1 Year Service

<u></u>	Alternator	r Controls and Auxiliaries V		Bearings
04/00/00 AILEIIIA	Inspect  Environmental conditions and cleanliness  Complete machine damage, loose parts, and earth bonds  Guards, screens, warning and safety labels  Test  Ambient temperature (inside and outside)	Test  AVR and PFC settings while alternator is running  Customer connections of auxiliaries  Function of auxiliaries  Synchronisation while alternator is running	Inspect Condition of windings  Test Insulation resistance of all windings Insulation resistance of rotor, exciter, and PMG Temperature sensors while alternator is running	Test  Temperature sensors while alternator is running  Replace Bearing grease  Clean Grease exhaust and trap
	Electrical nominal operating conditions and excitations while alternator is running     Vibration while alternator is running	Cooling Inspect Condition of fan  Test Condition of air filter  Clean Air filter	Rectifier Inspect Diodes and varistors	Terminal Box  Inspect ■ All alternator/customer connections and cabling

#### 10,000 Hours/2 Year Service

Alternator  Inspect  Coupling arrangement Environmental conditions and cleanliness Complete machine damage, losse parts, and earth  Alternator Controls and Auxiliaries Inspect Anti condensation hea Test AVR and PFC settings				
Alternator	Controls and Auxiliaries	Windings	Bearings	
Inspect	Inspect	Inspect	Test	
<ul><li>Coupling arrangement</li><li>Environmental conditions and cleanliness</li></ul>	Anti condensation heater	Condition of windings	Temperature sensors while alternator is running	
	Test	Test		
<ul> <li>Complete machine damage, loose parts, and earth bonds</li> </ul>	<ul> <li>AVR and PFC settings while alternator is running</li> </ul>	<ul><li>Insulation resistance of all windings</li></ul>	Replace  Bearing grease	
Guards, screens, warning	<ul> <li>Customer connections of auxiliaries</li> </ul>	<ul> <li>Temperature sensors while alternator is running</li> </ul>	Clean	
and safety labels	■ Function of auxiliaries		Grease exhaust and trap	
Test	<ul> <li>Synchronisation while alternator is running</li> </ul>		Grease exhaust and trap	
<ul> <li>Ambient temperature (inside and outside)</li> </ul>	· ·			
<ul> <li>Electrical nominal operating conditions and excitations while alternator is running</li> </ul>	Cooling	Rectifier	Terminal Box	
■ Vibration while alternator is	Inspect	Inspect	Inspect	
running	Condition of fan	■ Diodes and varistors	<ul> <li>All alternator/customer connections and cabling</li> </ul>	
	Test			
	Condition of air filter			
	Clean			
	Air filter			

#### S4/S5/S6 Alternator 30,000 Hours/5 Year Service Kits

For the 30,000 hour service interval we recommend replacing several components in order to optimise the alternator's performance.

For the S4/S5/S6 alternator, the kits detailed in this table contain all parts necessary to execute the maintenance and repairs.

Frame	Part Number	Description	
S4	A053M965	Heater Kit UL 220-260V	
S4	A053M957	Heater Kit UL 110-125V	
S5/S6	A053N002	Heater Kit UL 220-260V	
S5/S6	A053M968	Heater Kit UL 110-125V	

	Kit Number	Co	ntents
	<b>A051C225</b> (HC4/S4 1 Bearing 30,000 Hour Service Kit)	_	Rectifier Service Kit NDE Bearing Kit
	<b>A051C230</b> (HC4/S4 2 Bearing 30,000 Hour Service Kit)		Rectifier Service Kit DE and NDE Bearing Kit
	<b>A051C232</b> (HC5/ S5/S5D 1 SEALED Bearing 30,000 Hour Service Kit)	_	Rectifier Service Kit NDE Bearing Kit
	A051Z125 (HC5 / S5 1 RE-GREASABLE Bearing 30,000 Hour Service Kit		Rectifier Service Kit Regrease NDE Bearing Kit Cartridge and Cap
	A051C234 (HC5 / S5 2 SEALED Bearing 30,000 Hour Service Kit)		Rectifier Service Kit Sealed DE and NDE Bearing Kit Cartridge and Cap
١	A051Z131 (HC5 / S5 2 RE-GREASABLE Bearing 30,000 Hour Service Kit)		Rectifier Service Kit Regrease DE and NDE Bearing Kit Cartridge and Cap
l	A051C237 (HC6/S6/S6L1D G-H Core 1 SEALED Bearing 30,000 Hour Service Kit)		Rectifier Service Kit Sealed DE and NDE Bearing Kit Cartridge and Cap
l	A051C243 (HC6/S6/S6L1D G-H Core 2 SEALED Bearing 30,000 Hour Service Kit)		Rectifier Service Kit Sealed DE and NDE Bearing Kit Cartridge and Cap
	A059R029 (S6L1D C-F Core 2 SEALED Bearing 30,000 Hour Service Kit)		Rectifier Service Kit Sealed DE and NDE Bearing Kit Cartridge and Cap
	A051Z133 (HC6/S6 1 RE-GREASABLE Bearing 30,000 Hour Service Kit)		Rectifier Service Kit Regrease NDE Bearing Kit Cartridge and Cap
	A051Z137 (HC6/S6 2 RE-GREASABLE Bearing 30,000 Hour Service Kit)		Rectifier Service Kit Regrease DE and NDE Bearing Kit Cartridge and Cap

#### 30,000 Hours/5 Year Service

Alternator  Inspect  Controls and Auxiliaries  Replace  Coupling arrangement  Environmental conditions and cleanliness  Complete machine damage, losse parts, and earth				
Alternator	Controls and Auxiliaries	Windings	Bearings	
nspect	Replace	Inspect	Replace	
Coupling arrangement Environmental conditions	Anti condensation heater	■ Condition of Windings	■ Bearings (sealed & re-greasable	
and cleanliness	Test	Test	Bearing grease	
Complete machine damage, loose parts, and earth bonds	<ul> <li>AVR and PFC settings while alternator is running</li> </ul>	Insulation resistance of all windings	Test	
Guards, screens, warning and safety labels	<ul> <li>Customer connections of auxiliaries</li> </ul>	<ul> <li>Temperature sensors while alternator is running</li> </ul>	<ul> <li>Temperature sensors while alternator is running</li> </ul>	
and salety labels	■ Function of auxiliaries	Insulation resistance of		
lest .	Synchronisation while	rotor, exciter and PMG	Clean	
<ul> <li>Ambient temperature (inside and outside)</li> </ul>	alternator is running		Grease exhaust & trap (re-greasable bearings onl	
<ul> <li>Electrical nominal operating conditions and excitations while alternator is running</li> </ul>	Cooling	Rectifier	Terminal Box	
■ Vibration while alternator is	Inspect	Replace	Inspect	
running	Condition of fan	■ Diodes and varistors	<ul> <li>All alternator/customer connections and cabling</li> </ul>	
	Test			
	Condition of air filter			
	Clean			
	■ Air filter			

## P7 Alternator

# Alternator

Commission Po

Post Commission 6 Month Service 1,000 Hour 1 Year Service 10,000 Hours 2 Year Service 30,000 Hours 5 Year Service



_
+
σ
Ε
₫
ā
~
ב

#### Commission

Alternator	Controls and Auxiliaries	Windings	Bearings
nspect	Inspect	Inspect	Inspect
<ul> <li>Alternator rating</li> </ul>	Synchronisation settings	■ Condition of windings	■ Condition of bearings
Bedplate arrangement		<ul> <li>Customer settings for</li> </ul>	<ul> <li>Customer settings for</li> </ul>
Coupling arrangement	Test	temperature sensors	temperature sensors
■ Environmental conditions	■ Initial AVR and PFC set up		
and cleanliness	AVR and PFC settings	Test	Test
Complete machine damage, loose parts and earth bonds	settings while alternator is running	<ul> <li>Insulation resistance of all windings (P7 test for LV/MV)</li> </ul>	<ul> <li>Temperature sensors while alternator is running</li> </ul>
<ul> <li>Guards, screens, warning and safety labels</li> </ul>	<ul> <li>Customer connections of auxiliaries</li> </ul>	<ul> <li>Temperature sensors while alternator is running</li> </ul>	
Maintenance access	Function of auxiliaries		
	Synchronisation while		
Test	alternator is running		
<ul> <li>Ambient temperature (inside and outside)</li> </ul>	Cooling	Rectifier	Terminal Box
■ Electrical nominal operating	Inspect	Inspect	Inspect
conditions and excitations while alternator is running	<ul> <li>Air flow (rate and direction while alternator is running)</li> </ul>	■ Diodes and varistors	<ul> <li>All alternator/customer connections and cabling</li> </ul>
<ul> <li>Vibration while alternator is running</li> </ul>	Condition of fan		
	Test		
	Condition of air filter		

#### Post Commission 250 Hours/6 Months

Post Commission 250 Hours	/6 Months		
Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect     Environmental conditions and cleanliness     Complete machine damage, loose parts, and earth bonds     Guards, screens, warning and safety labels  Test     Ambient temperature (inside and outside)     Electrical nominal operating	Test  AVR and PFC settings while alternator is running Function of auxiliaries Synchronisation while alternator is running	Inspect Condition of windings  Test Insulation resistance of all windings (P7 test for LV/MV) Insulation resistance of rotor, exciter and PMG Temperature sensors while alternator is running	Inspect Condition of bearings  Test Temperature sensors while alternator is running  Clean Grease exhaust and trap (Re-greasable bearings only)  Replace Grease for re-greasable bearings
conditions and excitations while alternator is running  Vibration while alternator is running	Cooling  Inspect Condition of fan  Test Condition of air filter  Clean Air filter	Rectifier  Inspect  Diodes and varistors	Terminal Box Inspect ■ All alternator/customer connections and cabling

÷	Ξ
Ċ	۲
•	
3	
(	ľ
±	Ξ
3	1
	_
۲	7
-	-

#### b 1,000 Hours/1 Year Service

· ·			
Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect	Test	Inspect	Inspect
<ul> <li>Environmental conditions and cleanliness</li> </ul>	<ul> <li>AVR and PFC settings while alternator is running</li> </ul>	■ Condition of windings	Condition of bearings
Complete machine damage, loose parts, and earth bonds Guards, screens, warning and safety labels  Test Ambient temperature (inside and outside)	Customer connections of auxiliaries     Function of auxiliaries     Synchronisation while alternator is running	■ Insulation resistance of all windings (P7 test for LV/MV) ■ Insulation resistance of rotor, exciter, and PMG ■ Temperature sensors while alternator is running	Test ■ Temperature sensors while alternator is running  Clean ■ Grease exhaust and trap (Re-greasable bearings only)  Replace ■ Grease for re-greasable
<ul> <li>Electrical nominal operating conditions and excitations while alternator is running</li> </ul>			bearings
Vibration while alternator is	Cooling	Rectifier	Terminal Box
running	Inspect	Inspect	Inspect
	Condition of fan	■ Diodes and varistors	<ul> <li>All alternator/customer connections and cabling</li> </ul>
	Test ■ Condition of air filter		
	Clean ■ Air filter		

#### 10,000 Hours/2 Year Service

10,000 Hours/2 year Service				
Alternator	Controls and Auxiliaries	Windings	Bearings	
Inspect	Inspect	Inspect	Inspect	
Coupling arrangement	Anti condensation heater	Condition of windings	Condition of bearings	
<ul> <li>Environmental conditions and cleanliness</li> <li>Complete machine damage, loose parts, and earth bonds</li> <li>Guards, screens, warning and safety labels</li> <li>Test</li> <li>Ambient temperature (inside and outside)</li> </ul>	AVR and PFC settings while alternator is running     Customer connections of auxiliaries     Function of auxiliaries     Synchronisation while alternator is running	Test ■ Insulation resistance of all windings (P7 test for LV/MV) ■ Temperature sensors while alternator is running	Test  Temperature sensors while alternator is running  Clean Grease exhaust and trap (Re-greasable bearings only)  Replace Grease for re-greasable bearings	
<ul> <li>Electrical nominal operating conditions and excitations while alternator is running</li> </ul>	Cooling	Rectifier	Terminal Box	
■ Vibration while alternator is running	Inspect Condition of fan  Test Condition of air filter  Clean Air filter	Inspect ■ Diodes and varistors	Inspect ■ All alternator/customer connections and cabling	

#### P7 Alternator 30,000 Hours/5 Year Service Kits

For the 30,000 hour service interval we recommend replacing several components in order to optimise the alternator's performance.

For the P7 alternator, the kits detailed in this table contain all parts necessary to execute the maintenance and repairs.

Kit Number	Contents
A051C251 (P7/S7 LV & S7 HV 1 RE-GREASABLE Bearing 30,000 Hour Service Kit)	<ul><li>Rectifier Service Kit</li><li>NDE Bearing Kit</li><li>Cartridge and Cap</li></ul>
A051Z145 (P7/S7 LV & S7 HV 1 SEALED Bearing 30,000 HourService Kit)	<ul><li>Rectifier Service Kit</li><li>NDE Bearing Kit</li><li>Cartridge and Cap</li></ul>
A051C255 (P7 A-E core/S7 LV C-F core 2 RE-GREASABLE Bearing 30,000 Hour Service Kit)	<ul><li>Rectifier Service Kit</li><li>DE Bearing Kit</li><li>Cartridge and Cap</li></ul>
A051C257 (P7 F-G core/S7 LV G-J core & S7 HV G-J core 2 RE-GREASABLE Bearing 30,000 Hour Service Kit)	<ul><li>Rectifier Service Kit</li><li>DE Bearing Kit</li><li>Cartridge and Cap</li></ul>

Frame	Part Number	Description
P7 A-F	A053N003	Heater Kit UL 220-260V
P7 A-F	A053M969	Heater Kit UL 110-125V
P7 G-H	A053N109	Heater Kit UL 220-260V
P7 G-H	A053M999	Heater Kit UL 110-125V

#### 30,000 Hours/5 Year Service

Alternator	Controls and Auxiliaries	Windings	Bearings
nspect	Replace	Inspect	Replace
Coupling arrangement  Environmental conditions	Anti condensation heater	Condition of windings	Bearings (Sealed & re-greasable)
Environmental conditions and cleanliness     Complete machine damage, loose parts, and earth bonds     Guards, screens, warning and safety labels  Test     Ambient temperature (inside	Test  AVR and PFC settings while alternator is running  Customer connections of auxiliaries  Function of auxiliaries  Synchronisation while alternator is running	■ Insulation resistance of all windings (P7 test for LV/MV) ■ Temperature sensors while alternator is running ■ Insulation resistance of rotor, exciter and PMG	<ul> <li>Bearing grease</li> <li>Test</li> <li>Temperature sensors while alternator is running</li> <li>Clean</li> <li>Grease exhaust &amp; trap</li> </ul>
and outside)  Electrical nominal operating conditions and excitations while alternator is running	Cooling	Rectifier	(re-greasable bearings only  Terminal Box
Vibration while alternator is running	Inspect Condition of fan  Test Condition of air filter  Clean Air filter	Replace  Diodes and varistors	Inspect  All alternator/customer connections and cabling

#### S7 Alternator



S7
Alternator

Commission F

Post Commission 6 Month Service 1,000 Hour 1 Year Service 10,000 Hours 2 Year Service 30,000 Hours 5 Year Service



_
۶
π
Ľ
٩
۵
_
U.

#### Commission

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect	Inspect	Inspect	Inspect
<ul> <li>Alternator rating</li> </ul>	Synchronisation settings	■ Condition of windings	■ Condition of bearings
■ Bedplate arrangement		Customer settings for	Customer settings for
<ul> <li>Coupling arrangement</li> </ul>	Test	temperature sensors	temperature sensors
<ul> <li>Environmental conditions</li> </ul>	■ Initial AVR and PFC set up		
and cleanliness	<ul> <li>AVR and PFC settings</li> </ul>	Test	Test
<ul> <li>Complete machine damage, loose parts and earth bonds</li> </ul>	settings while alternator is running	<ul> <li>Insulation resistance of all windings (P7 test for LV/MV)</li> </ul>	<ul> <li>Temperature sensors while alternator is running</li> </ul>
<ul> <li>Guards, screens, warning and safety labels</li> </ul>	<ul> <li>Customer connections of auxiliaries</li> </ul>	<ul> <li>Temperature sensors while alternator is running</li> </ul>	
Maintenance access	Function of auxiliaries		
	Synchronisation while		
Test	alternator is running		
<ul> <li>Ambient temperature (inside and outside)</li> </ul>	Cooling	Rectifier	Terminal Box
■ Electrical nominal operating	Inspect	Inspect	Inspect
conditions and excitations while alternator is running	<ul> <li>Air flow (rate and direction while alternator is running)</li> </ul>	■ Diodes and varistors	<ul> <li>All alternator/customer connections and cabling</li> </ul>
<ul> <li>Vibration while alternator is running</li> </ul>	Condition of fan		
	Test		
	Condition of air filter		

#### Post Commission 250 Hours/6 Months

1 OST CONTINUES TO THOUGH OF MONTHS			
Alternator	Controls and Auxiliaries	Windings	Bearings
Alternator Inspect	Test	Inspect	Inspect
Environmental conditions and cleanliness	<ul> <li>AVR and PFC settings while alternator is running</li> </ul>	Condition of windings	Condition of bearings
Complete machine damage, loose parts, and earth bonds Guards, screens, warning and safety labels  Test Ambient temperature (inside and outside) Electrical nominal operating	<ul> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	Test  Insulation resistance of all windings (P7 test for LV/MV)  Insulation resistance of rotor, exciter and PMG  Temperature sensors while alternator is running	Test  Temperature sensors while alternator is running  Clean Grease exhaust and trap (Re-greasable bearings only)  Replace Grease for re-greasable bearings
conditions and excitations while alternator is running	Cooling	Rectifier	Terminal Box
■ Vibration while alternator is running	Inspect Condition of fan Heat exchanger seals (S7W only)  Test Condition of air filter  Clean Air filter	Inspect ■ Diodes and varistors	Inspect ■ All alternator/customer connections and cabling

	π
	↽
	Œ
	◁
	•
•	J.
	٠.

#### □ 1,000 Hours/1 Year Service

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect	Test	Inspect	Inspect
Inspect     Environmental conditions and cleanliness     Complete machine damage, loose parts, and earth bonds     Guards, screens, warning and safety labels  Test     Ambient temperature (inside and outside)     Electrical nominal operating	<ul> <li>AVR and PFC settings while alternator is running</li> <li>Customer connections of auxiliaries</li> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	Test Insulation resistance of all windings (P7 test for LV/MV) Insulation resistance of rotor, exciter, and PMG Temperature sensors while alternator is running	■ Condition of bearings  Test ■ Temperature sensors while alternator is running  Clean ■ Grease exhaust and trap (Re-greasable bearings only)  Replace ■ Grease for re-greasable bearings
conditions and excitations while alternator is running	Cooling	Rectifier	Terminal Box
<ul> <li>Vibration while alternator is running</li> </ul>	Inspect ■ Condition of fan ■ Heat exchanger seals  Test ■ Condition of air filter  Clean ■ Air filter	Inspect ■ Diodes and varistors	Inspect ■ All alternator/customer connections and cabling

#### 10,000 Hours/2 Year Service

3	10,000 Hours/2 fear Service	;		
<u> </u>	Alternator	Controls and Auxiliaries	Windings	Bearings
of Alternation	Inspect Coupling arrangement Environmental conditions and cleanliness Complete machine damage, loose parts, and earth bonds Guards, screens, warning and safety labels  Test Ambient temperature (inside	Inspect Anti condensation heater  Test AVR and PFC settings while alternator is running Customer connections of auxiliaries Function of auxiliaries Synchronisation while alternator is running	Inspect Condition of windings  Test Insulation resistance of all windings (P7 test for LV/MV) Temperature sensors while alternator is running	Inspect Condition of bearings  Test Temperature sensors while alternator is running  Clean Grease exhaust and trap (Re-greasable bearings only)  Replace Grease for re-greasable
	and outside)  Electrical nominal operating conditions and excitations while alternator is running  Vibration while alternator is running	Cooling  Inspect Condition of fan Heat exchanger seals (S7W only)  Test Condition of air filter  Clean Air filter	Rectifier  Inspect Diodes and varistors	bearings  Terminal Box  Inspect  All alternator/customer connections and cabling

#### S7 Alternator 30,000 Hours/5 Year Service Kits

For the 30,000 hour service interval we recommend replacing several components in order to optimise the alternator's performance.

For the S7 alternator, the kits detailed in this table contain all parts necessary to execute the maintenance and repairs.

Frame	Part Number	Description
S7 C-G	A053N003	Heater Kit UL 220-260V
S7 C-G	A053M969	Heater Kit UL 110-125V
S7 H-J	A053N109	Heater Kit UL 220-260V
S7 H-J	A053M999	Heater Kit UL 110-125V
S7 HV	A053M999 A064T028	Heater Kit UL 110V Heater Kit UL 240V

Kit Number	Contents
A051C251 (P7/S7 LV/S7 WLV & S7 HV 1 RE-GREASABLE Bearing 30,000 Hour Service Kit)	<ul><li>Rectifier Service Kit</li><li>NDE Anti-Friction Bearing K</li><li>Cartridge and Cap</li></ul>
A051Z145 (P7/S7 LV & S7 HV 1 SEALED Bearing 30,000 Hour Service Kit)	<ul><li>Rectifier Service Kit</li><li>NDE Anti-Friction Bearing K</li><li>Cartridge and Cap</li></ul>
AO706H555 (S7 LV K core 1 BEARING RE-GREASABLE Bearing 30,000 Hour Service Kit)	<ul><li>Rectifier Service Kit</li><li>DE Anti-Friction Bearing Kit</li><li>Cartridge and Cap</li></ul>
A051C255 (P7 A-E core/S7 LV C-F core & S7 WLV D-J core 2 REGREASABLE Bearing 30,000 Hour Service Kit)	<ul><li>Rectifier Service Kit</li><li>DE Anti-Friction Bearing Kit</li><li>Cartridge and Cap</li></ul>
AO706H557 (S7 LV K core 2 BEARING RE-GREASABLE Bearing 30,000 Hour Service Kit)	<ul><li>Rectifier Service Kit</li><li>DE Anti-Friction Bearing Kit</li><li>Cartridge and Cap</li></ul>
A051C257 (P7 F-G core/S7 LV G-J core /S7 WLV D-J core & S7 HV G-J core 2 RE-GREASABLE Bearing 30,000 Hour Service Kit)	<ul><li>Rectifier Service Kit</li><li>DE Anti-Friction Bearing Kit</li><li>Cartridge and Cap</li></ul>

#### 30,000 Hours/5 Year Service

Replace  Anti condensation heater	Inspect	Replace
<ul> <li>Anti condensation heater</li> </ul>		
	Condition of windings	<ul> <li>Anti-friction bearings (sealed &amp; re-greasable)</li> </ul>
Test	Test	■ Bearing grease
<ul> <li>AVR and PFC settings while alternator is running</li> </ul>	<ul> <li>Insulation resistance of all windings (S7 test for LV)</li> </ul>	Test
<ul> <li>Customer connections of auxiliaries</li> </ul>	<ul> <li>Temperature sensors while alternator is running</li> </ul>	■ Temperature sensors while alternator is running
■ Function of auxiliaries	Insulation resistance of	
	Totol, exoler and rivid	Clean
atternation is running		Grease exhaust & trap (re-greasable bearings only)
Cooling	Rectifier	Terminal Box
Inspect	Replace	Inspect
Condition of fan	■ Diodes and varistors	<ul> <li>All alternator/customer</li> </ul>
<ul><li>Heat exchanger seals (S7W only)</li></ul>		connections and cabling
Test		
Condition of air filter		
Clean		
Air filter		
	AVR and PFC settings while alternator is running  Customer connections of auxiliaries  Function of auxiliaries  Synchronisation while alternator is running  Cooling  Inspect  Condition of fan  Heat exchanger seals (S7W only)  Test  Condition of air filter  Clean	<ul> <li>AVR and PFC settings while alternator is running</li> <li>Customer connections of auxiliaries</li> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> <li>Insulation resistance of all windings (S7 test for LV)</li> <li>Temperature sensors while alternator is running</li> <li>Insulation resistance of rotor, exciter and PMG</li> </ul> Cooling Rectifier Inspect <ul> <li>Condition of fan</li> <li>Heat exchanger seals (S7W only)</li> </ul> Test <ul> <li>Condition of air filter</li> </ul> Clean

#### S7 Water-Cooled Alternator 50,000 Hours Service Parts

For the 50,000 hour service interval we recommend inspecting and replacing if necessary non drive end and drive end bearing shells in order to optimise the alternator's performance.

Part Number	Contents
A067T920	■ Drive Bearing Shell
A067T658	■ Drive Bearing Shell

#### 등 50,000 Hours

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect	Test	Inspect	Replace
<ul> <li>Coupling arrangement</li> <li>Environmental conditions and cleanliness</li> <li>Complete machine damage, loose parts, and earth bonds</li> <li>Guards, screens, warning and safety labels</li> </ul> Test <ul> <li>Ambient temperature (inside and outside)</li> </ul>	<ul> <li>AVR and PFC settings while alternator is running</li> <li>Customer connections of auxiliaries</li> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	Condition of windings  Test     Insulation resistance of all windings (S7 test for LV)     Temperature sensors while alternator is running     Insulation resistance of rotor, exciter and PMG	<ul> <li>Bearing shells</li> <li>Test</li> <li>Temperature sensors while alternator is running</li> <li>Clean</li> <li>Grease exhaust &amp; trap (re-greasable bearings only)</li> </ul>
<ul> <li>Electrical nominal operating conditions and excitations</li> </ul>	Cooling	Rectifier	Terminal Box
<ul> <li>while alternator is running</li> <li>Vibration while alternator is running</li> </ul>	Inspect Condition of fan Heat exchanger seals Bearing shells  Test Condition of air filter  Clean Air filter	Inspect ■ Diodes and varistors	Inspect ■ All alternator/customer connections and cabling

#### P80 Alternator



## P80 Alternator

Commission

Post Commission 6 Month Service 1,000 Hour 1 Year Service 10,000 Hours 2 Year Service 30,000 Hours 5 Year Service



	c	
-	č	=
Ξ	5	
	ς	Ĺ
	r	-
	ŝ	
ı	c	ľ
	ř	
-	-	
4	c	1
	7	7
C		3
2	-	Ξ
ς	J	
Ċ	3	Ĺ
-		

#### Commission

5					
A	Alternator	Controls and Auxiliaries	Windings	Bearings	
3 1	nspect	Inspect	Inspect	Inspect	
	Alternator rating Bedplate arrangement Coupling arrangement Environmental conditions and cleanliness Complete machine damage, loose parts and earth bonds Guards, screens, warning and safety labels Maintenance access	Synchronisation settings  Test     Initial AVR and PFC set up     AVR and PFC settings settings while alternator is running     Customer connections of auxiliaries     Function of auxiliaries     Synchronisation while alternator is running	Condition of windings Customer settings for temperature sensors  Test Insulation resistance of all windings (P80 test for MV/HV) Temperature sensors while alternator is running	<ul> <li>Condition of bearings</li> <li>Customer settings for temperature sensors</li> <li>Test</li> <li>Temperature sensors while alternator is running</li> </ul>	
ŀ	Ambient temperature (inside and outside)	Cooling	Rectifier	Terminal Box	
		Inspect Air flow (rate and direction while alternator is running) Condition of fan  Test Condition of air filter	Inspect ■ Diodes and surge suppressors	Inspect ■ All alternator/customer connections and cabling	

#### Post Commission 250 Hours/6 Months

3	FUSE COMMINISSION 230 HOURS/O MONUIS			
	Alternator	Controls and Auxiliaries	Windings	Bearings
	Inspect     Environmental conditions and cleanliness     Complete machine damage, loose parts, and earth bonds     Guards, screens, warning and safety labels  Test     Ambient temperature (inside and outside)     Electrical nominal operating conditions and excitations	Test  AVR and PFC settings while alternator is running Function of auxiliaries Synchronisation while alternator is running	Inspect Condition of windings  Test Insulation resistance of all windings (P80 test for MV/HV) Insulation resistance of rotor, exciter and PMG Temperature sensors while alternator is running	Inspect Condition of bearings  Test Temperature sensors while alternator is running  Clean Grease exhaust and trap (Re-greasable bearings only)  Replace Grease for re-greasable bearings
	while alternator is running	Cooling	Rectifier	Terminal Box
	■ Vibration while alternator is running	Inspect ■ Condition of fan  Test ■ Condition of air filter  Clean ■ Air filter	Inspect ■ Diodes and surge suppressors	Inspect ■ All alternator/customer connections and cabling

	J
	I
	٦

#### □ 1,000 Hours/1 Year Service

5	Alternator	Controls and Auxiliaries	Windings	Bearings
ו מו אונפווומ	Inspect     Environmental conditions and cleanliness     Complete machine damage, loose parts, and earth bonds     Guards, screens, warning and safety labels  Test     Ambient temperature (inside and outside)     Electrical nominal operating	Test  AVR and PFC settings while alternator is running  Customer connections of auxiliaries  Function of auxiliaries  Synchronisation while alternator is running	Inspect Condition of windings  Test Insulation resistance of all windings (P80 test for MV/HV) Insulation resistance of rotor, exciter, and PMG Temperature sensors while alternator is running	Inspect Condition of bearings  Test Temperature sensors while alternator is running  Clean Grease exhaust and trap (Re-greasable bearings only)  Replace Grease for re-greasable bearings
	conditions and excitations while alternator is running  Vibration while alternator is running	Cooling  Inspect Condition of fan  Test Condition of air filter  Clean Air filter	Rectifier  Inspect  Diodes and surge suppressors	Terminal Box  Inspect  All alternator/customer connections and cabling

#### 10,000 Hours/2 Year Service

10,000 nours/2 rear service				
	Alternator	Controls and Auxiliaries	Windings	Bearings
	Inspect  Coupling arrangement  Environmental conditions and cleanliness  Complete machine damage, loose parts, and earth bonds  Guards, screens, warning and safety labels  Test  Ambient temperature (inside and outside)	Inspect  Anti condensation heater  Test  AVR and PFC settings while alternator is running  Customer connections of auxiliaries  Function of auxiliaries  Synchronisation while alternator is running	Inspect Condition of windings  Test Insulation resistance of all windings (P80 test for MV/HV) Temperature sensors while alternator is running	Inspect Condition of bearings  Test Temperature sensors while alternator is running  Clean Grease exhaust and trap (Re-greasable bearings only)  Replace Grease for re-greasable bearings
	<ul> <li>Electrical nominal operating conditions and excitations while alternator is running</li> </ul>	Cooling	Rectifier	Terminal Box
	Vibration while alternator is running	Inspect Condition of fan  Test Condition of air filter  Clean Air filter	Inspect ■ Diodes and surge suppressors	Inspect ■ All alternator/customer connections and cabling

#### P80 Alternator 30,000 Hours/5 Year Service Kits

For the 30,000 hour service interval we recommend replacing several components in order to optimise the alternator's performance.

For the P80 alternator, the kits detailed in this table contain all parts necessary to execute the maintenance and repairs.


Kit Number	Contents
<b>A051C282</b> (P80 1 Bearing 30,000 Hour Service Kit)	■ Rectifier Service Kit ■ NDE Bearing Kit
<b>A051C285</b> (P80 2 Bearing 30,000 Hour Service Kit)	Rectifier Service Kit Bearing Kit Frame R, S, & T
<b>A051C291</b> (P80 2 Bearing 30,000 Hour Service Kit)	■ Rectifier Service Kit ■ Bearing Kit Frame X, Y, & Z

Frame	Part Number	Description
P80	45-1029	Heater Kit UL

#### 30,000 Hours/5 Year Service

30,000 Hours/5 fear Service			
Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect	Replace	Inspect	Replace
Coupling arrangement     Environmental conditions	Anti condensation heater	Condition of windings	Bearings (sealed & re-greasable)
and cleanliness  Complete machine damage, loose parts, and earth bonds  Guards, screens, warning and safety labels	Test  AVR and PFC settings while alternator is running  Customer connections of auxiliaries  Function of auxiliaries  Synchronisation while alternator is running	Insulation resistance of all windings (P80 test for MV/HV)     Temperature sensors while alternator is running     Insulation resistance of rotor, exciter and PMG	<ul> <li>Bearing grease</li> <li>Test</li> <li>Temperature sensors while alternator is running</li> <li>Clean</li> <li>Grease exhaust &amp; trap</li> </ul>
<ul> <li>Ambient temperature (inside and outside)</li> <li>Electrical nominal operating conditions and excitations</li> </ul>	Cooling	Rectifier	(re-greasable bearings only)  Terminal Box
while alternator is running  Vibration while alternator is running	Inspect ■ Condition of fan  Test ■ Condition of air filter	Replace  Diodes and surge suppressors	Inspect ■ All alternator/customer connections and cabling

#### S9 Alternator



S9 Alternator

Commission Po

Post Commission 6 Month Service 1,000 Hour 1 Year Service 10,000 Hours 2 Year Service 30,000 Hours 5 Year Service





	C		3
_	ì	=	3
Ξ	5		
	ι	١	
	ø		Ė
	1	-	
	2	-	
	r	٦	٠
	ì	1	1
=	•		
=	Ξ	-	i
4	Ę		ľ
		1	7
ı		۲	3
3	•	•	
c	ı	r	1
3		•	-

#### Commission

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect	Inspect	Inspect	Inspect
Alternator rating     Bedplate arrangement     Coupling arrangement     Environmental conditions and cleanliness     Complete machine damage, loose parts and earth bonds     Guards, screens, warning and safety labels     Maintenance access	<ul> <li>Synchronisation settings</li> <li>Test</li> <li>Initial AVR and PFC set up</li> <li>AVR and PFC settings settings while alternator is running</li> <li>Customer connections of auxiliaries</li> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	Condition of windings Customer settings for temperature sensors  Test Insulation resistance of all windings (P80 test for MV/HV) Temperature sensors while alternator is running	<ul> <li>Condition of bearings</li> <li>Customer settings for temperature sensors</li> <li>Test</li> <li>Temperature sensors while alternator is running</li> </ul>
<ul> <li>Ambient temperature (inside and outside)</li> </ul>	Cooling	Rectifier	Terminal Box
Electrical nominal operating conditions and excitations while alternator is running     Vibration while alternator is running	Inspect  Air flow (rate and direction while alternator is running)  Condition of fan  Test  Condition of air filter	Inspect ■ Diodes and surge suppressors	Inspect ■ All alternator/customer connections and cabling

#### Post Commission 250 Hours/6 Months

1 OST COMMINISSION 250 MONTHS				
Alternator	Controls and Auxiliaries	Windings	Bearings	
Inspect     Environmental conditions and cleanliness     Complete machine damage, loose parts, and earth bonds	Test  AVR and PFC settings while alternator is running Function of auxiliaries Synchronisation while alternator is running	Inspect Condition of windings  Test Insulation resistance of all windings (P80 test for	Inspect Condition of bearings  Test Temperature sensors while alternator is running	
Guards, screens, warning and safety labels  Test Ambient temperature (inside and outside)  Electrical nominal operating conditions and excitations		MV/HV)  Insulation resistance of rotor, exciter and PMG  Temperature sensors while alternator is running	Clean  Grease exhaust and trap (Re-greasable bearings only)  Replace Grease for re-greasable bearings	
while alternator is running  Vibration while alternator is running	Inspect Condition of fan  Test Condition of air filter  Clean Air filter	Rectifier  Inspect  Diodes and surge suppressors	Terminal Box  Inspect ■ All alternator/customer connections and cabling	

#### a 1,000 Hours/1 Year Service

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect  Environmental conditions and cleanliness  Complete machine damage, loose parts, and earth bonds  Guards, screens, warning and safety labels  Test  Ambient temperature (inside and outside)  Electrical nominal operating	Test  AVR and PFC settings while alternator is running  Customer connections of auxiliaries  Function of auxiliaries  Synchronisation while alternator is running	Inspect Condition of windings  Test Insulation resistance of all windings (P80 test for MV/HV) Insulation resistance of rotor, exciter, and PMG Temperature sensors while alternator is running	Inspect Condition of bearings  Test Temperature sensors while alternator is running  Clean Grease exhaust and trap (Re-greasable bearings only)  Replace Grease for re-greasable bearings
conditions and excitations while alternator is running  Vibration while alternator is running	Cooling Inspect Condition of fan  Test Condition of air filter  Clean Air filter	Rectifier  Inspect  Diodes and surge suppressors	Terminal Box  Inspect  All alternator/customer connections and cabling

#### 10,000 Hours/2 Year Service

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect  Coupling arrangement Environmental conditions and cleanliness Complete machine damage,	Inspect ■ Anti condensation heater  Test ■ AVR and PFC settings while	Inspect ■ Condition of windings  Test ■ Insulation resistance of	Inspect Condition of bearings  Test Temperature sensors while
loose parts, and earth bonds  Guards, screens, warning and safety labels  Test  Ambient temperature (inside and outside)	alternator is running  Customer connections of auxiliaries  Function of auxiliaries  Synchronisation while alternator is running	all windings (P80 test for MV/HV)     Temperature sensors while alternator is running	alternator is running  Clean  Grease exhaust and trap (Re-greasable bearings only)  Replace  Grease for re-greasable bearings
Electrical nominal operating conditions and excitations while alternator is running     Vibration while alternator is running	Cooling Inspect Condition of fan  Test Condition of air filter  Clean Air filter	Rectifier  Inspect  Diodes and surge suppressors	Terminal Box  Inspect ■ All alternator/customer connections and cabling

#### S9 Alternator 30,000 Hours/5 Year Service Kits

For the 30,000 hour service interval we recommend replacing several components in order to optimise the alternator's performance.

For the S9 alternator, the kits detailed in this table contain all parts necessary to execute the maintenance and repairs.

Kit Number	Contents
<b>A065P433</b> (S9 1 Bearing 30,000 Hour Service Kit)	■ Rectifier Service Kit ■ NDE Bearing Kit
<b>A065P434</b> (S9 2 Bearing 30,000 Hour Service Kit)	■ Rectifier Service Kit ■ Bearing Kit Frame A - D
<b>A065P435</b> (S9 2 Bearing 30,000 Hour Service Kit)	■ Rectifier Service Kit ■ Bearing Kit Frame E - F
<b>A065P436</b> (S9 2 Bearing 30,000 Hour Service Kit)	■ Rectifier Service Kit ■ Bearing Kit Frame G - H

Frame	Part Number	Description
S9	A059S757	F9 Heater Kit

#### 30,000 Hours/5 Year Service

Alternator	Controls and Auxiliaries	Windings	Bearings
Coupling arrangement     Environmental conditions and cleanliness     Complete machine damage, loose parts, and earth bonds     Guards, screens, warning and safety labels  Test     Ambient temperature (inside and outside)	Replace Anti condensation heater  Test AVR and PFC settings while alternator is running Customer connections of auxiliaries Function of auxiliaries Synchronisation while alternator is running	Inspect Condition of windings  Test Insulation resistance of all windings (P80 test for MV/HV) Temperature sensors while alternator is running Insulation resistance of rotor, exciter and PMG	Replace Bearings (sealed & re-greasable) Bearing grease  Test Temperature sensors while alternator is running  Clean Grease exhaust & trap (re-greasable bearings only)
Electrical nominal operating conditions and excitations while alternator is running     Vibration while alternator is running	Inspect Condition of fan  Test Condition of air filter	Rectifier  Replace  Diodes and surge suppressors	Terminal Box Inspect  All alternator/customer connections and cabling

#### Guaranteed **STAMFORD**®

We guarantee that every product we produce matches the quality, robustness, and proven performance you expect from the STAMFORD range. Built to our quality assured standards, STAMFORD products benefit from a global support network, extensive research and development, and world-leading expertise.

Where people need power, businesses rely on genuine STAMFORD alternators. Proven expertise in design, development, manufacturing, customer support and servicing, ensures quality in every aspect of our business.

Visit **stamford-avk.com/verify** to find out how we are protecting our customers and their businesses against the dangers of illegal, counterfeit and imitation products and taking action.



#### Ultimate Peace of Mind

Selecting the right alternator for the right application in today's complex world is our goal - making your life simpler. We understand the performance requirements that each application and operating environment demands. Our knowledgeable and experienced Customer Engineers align individual customers' power needs with the most suitable alternator specification.

We take pride in our global reputation for Technical Support and After Sales Service, continually adding new, trained engineers in locations near to our customers, worldwide.

Our engineers are experienced professionals trained in electrical, electronic and mechanical engineering and are ready to help at any point in the **STAMFORD** alternator lifecycle, minimising risk of unexpected downtime.

What this means to you:

- 24 hour response to service emergencies,7 days a week
- Trained engineers available locally, speaking the local language
- Commissioning of alternators onsite
- Onsite bearing maintenance and bearing condition monitoring
- Onsite insulation integrity checks
- AVR and accessories set up onsite
- Extensive aftermarket distribution for genuine **STAMFORD** parts

#### stamford-avk@cummins.com www.stamford-avk.com









#### STAMFORD | AvK ™ P@WERING TOMORROW, TOGETHER